

**Q. LEASES****1.5 MW PORTABLE DIESEL GENERATOR, p. 3 of 3, \$12,000/Year****PUB 35.0**

**Please provide a history since its procurement of the usage of the 1.5 MW portable unit located in Trepassey, including the locations and the reasons for the usage.**

- A. Table 1 provides the usage history of the 1.5 MW portable diesel now located in Trepassey. It also indicates the locations and the reasons for the usage.

<p align="center"><b>Table 1</b></p> <p align="center"><b>Usage History of 1.5 MW Portable Generation Unit</b></p>					
<b>Date</b>	<b>Location</b>	<b>Purpose</b>	<b>Run Time (HRS)</b>	<b>Generation (kWh)</b>	<b>Fuel Used (L)</b>
20-Feb 99 to 6 – Mar-99	Corner Brook	Canada Winter Game - Standby	N/A	N/A	N/A
05-Aug-99	Trepassey	Testing	0.3	N/A	175
09-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	15.0	108,375	1,803
10-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	12.0		1,621
11-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	12.0		2,502
12-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	12.0		1,875
13-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	12.0		2,110
15-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	4.5		1,183
16-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	11.0		2,158
17-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	11.5		2,079
18-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	11.0		1,740
19-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	11.5		2,818
20-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	10.0		1,756
23-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	12.0		2,068
24-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	11.5		1,601

**Table 1**  
**Usage History of 1.5 MW Portable Generation Unit**

<b>Date</b>	<b>Location</b>	<b>Purpose</b>	<b>Run Time (HRS)</b>	<b>Generation (kWh)</b>	<b>Fuel Used (L)</b>
25-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	12.5		3,035
26-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	12.0		2,458
27-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	9.0		1,354
30-Aug-99	Lark Harbour	For Lark Harbour & Frenchman's Cove Project	8.0		1,249
06-Oct-99	St. Vincent's	Testing	0.3	N/A	N/A
14-Oct-99	St. Vincent's	To support planned upgrade of RVH-01	5.0	N/A	1,225
15-Oct-99	St. Vincent's	To support planned upgrade of RVH-01	5.0	N/A	1,193
18-Oct-99	St. Vincent's	To support planned upgrade of RVH-01	5.5	N/A	1,349
20-Oct-99	St. Vincent's	To support planned upgrade of RVH-01	6.3	N/A	1,614
21-Oct-99	St. Vincent's	To support planned upgrade of RVH-01	4.5	N/A	626
25-Oct-99	St. Vincent's	To support planned upgrade of RVH-01	4.8	N/A	806
27-Oct-99	St. Vincent's	To support planned upgrade of RVH-01	7.8	N/A	795
28-Oct-99	St. Vincent's	To support planned upgrade of RVH-01	7.3	N/A	741
01-Nov-99	St. Vincent's	To support planned upgrade of RVH-01	5.5	N/A	1,274
02-Nov-99	St. Vincent's	To support planned upgrade of RVH-01	6.0	N/A	453
04-Nov-99	St. Vincent's	To support planned upgrade of RVH-01	5.0	N/A	337
21-Dec-99	Trepassey	Testing	0.3	N/A	73
06-Jan-00	Trepassey	Testing	0.8	N/A	N/A
15-Feb-00	Trepassey	Testing	0.2	N/A	N/A
06-Oct-00	Trepassey	Testing	0.5	N/A	N/A
25-Jan-01	Trepassey	Testing	1.0	N/A	N/A
14-Mar-01	Trepassey	Testing	0.8	N/A	N/A
15-Mar-01	Trepassey	Testing	0.8	N/A	N/A
10-May-01	Lamaline	To accommodate reconductoring of LAU-02	N/A	N/A	N/A
15-May-01	Lamaline	To accommodate reconductoring of LAU-02	8.9	N/A	2,154
17-May-01	Lamaline	To accommodate reconductoring of LAU-02	6.5	N/A	1,475
23-May-01	Lamaline	To accommodate reconductoring of LAU-02	10.0	N/A	1,853
24-May-01	Lamaline	To accommodate reconductoring of LAU-02	6.0	N/A	1,362
29-May-01	Lamaline	To accommodate reconductoring of LAU-02	7.5	N/A	1,028

<b>Table 1</b> <b>Usage History of 1.5 MW Portable Generation Unit</b>					
<b>Date</b>	<b>Location</b>	<b>Purpose</b>	<b>Run Time (HRS)</b>	<b>Generation (kWh)</b>	<b>Fuel Used (L)</b>
31-May-01	Lamaline	To accommodate reconductoring of LAU-02	3.8	N/A	862
04-Jun-01	Lamaline	To accommodate reconductoring of LAU-02	4.1	22,648	906
05-Jun-01	Lamaline	To accommodate reconductoring of LAU-02	8.2		2,249
06-Jun-01	Lamaline	To accommodate reconductoring of LAU-02	2.5		796
07-Jun-01	Lamaline	To accommodate reconductoring of LAU-02	5.2		894
11-Jun-01	Lamaline	To accommodate reconductoring of LAU-02	4.8		853
19-Jun-01	Lamaline	To accommodate reconductoring of LAU-02	4.8		705
20-Jun-01	Lamaline	To accommodate reconductoring of LAU-02	5.1		1,103
July 01	Abraham's Cove	Located at ABC, for use during upgrading if load exceeded other capacity	0.0	0.0	0.0
Aug 01	Abraham's Cove	Located at ABC, for use during upgrading if load exceeded other capacity	0.0	0.0	0.0
Sep 01	Port-Aux-Basques	Located at GBS, but not used	0.0	0.0	0.0
04-Oct-01	Burnt Point	Testing	N/A	N/A	N/A
09-Oct-01	Burnt Point	Testing	0.8	N/A	148
16-Oct-01	Burnt Point	To supply various sections of OPL-02 during upgrade project	7.0	10,320	753
17-Oct-01	Burnt Point	To supply various sections of OPL-02 during upgrade project	5.8		697
19-Oct-01	Burnt Point	To supply various sections of OPL-02 during upgrade project	6.8		888
23-Oct-01	Burnt Point	To supply various sections of OPL-02 during upgrade project	6.5		685
24-Oct-01	Burnt Point	To supply various sections of OPL-02 during upgrade project	6.2		523
25-Oct-01	Burnt Point	To supply various sections of OPL-02 during upgrade project	5.1		360
26-Oct-01	Burnt Point	To supply various sections of OPL-02 during upgrade project	5.2		307
02-Nov-01	Burnt Point	To supply various sections of OPL-02 during upgrade project	5.6	3,740	1,281
04-Nov-01	Burnt Point	To provide supply during outage on 43L	8.2		1,310

<b>Table 1</b> <b>Usage History of 1.5 MW Portable Generation Unit</b>					
<b>Date</b>	<b>Location</b>	<b>Purpose</b>	<b>Run Time (HRS)</b>	<b>Generation (kWh)</b>	<b>Fuel Used (L)</b>
18-Nov-01	Burnt Point	To provide supply during outage on 65L	5.2		1,150
20-Dec-01	Trepassey	Testing	1.7	467	20
20-Feb-02	Trepassey	Testing to troubleshoot	0.8	890	174
11-Apr-02	Trepassey	Testing & Annual Inspection	1.5	1,192	278
17-Jul-02	Trepassey	Testing & Inspection	1.5	870	180
02-Oct-02	Trepassey	Testing	1.5	N/A	227
14-Nov-02	Trepassey	Testing	0.8	950	187
12-Mar-03	Trepassey	Testing	1.5	950	187
09-May-03	Trepassey	Testing	0.8	1,000	100
20-Jun-03	Trepassey	Testing	N/A	N/A	10
08-Jul-03	Trepassey	Testing	1.2	N/A	228
10-Jul-03	Trepassey	Replacing valves	N/A	N/A	10
06-Oct-03	Trepassey	Testing	1.2	1,000	295
11-Nov-03	Eastport	Testing	0.4	N/A	N/A
13-Nov-03	Eastport	Testing	8.2	N/A	2,487
14-Nov-03	Eastport	To support planned upgrade of GLV-02	N/A	31,835	9,210
17-Nov-03	Eastport	To support planned upgrade of GLV-02	N/A		
18-Nov-03	Eastport	To support planned upgrade of GLV-02	N/A		
19-Nov-03	Eastport	To support planned upgrade of GLV-02	N/A		
25-Nov-03	Eastport	To support planned upgrade of GLV-02	N/A		
26-Nov-03	Eastport	To support planned upgrade of GLV-02	N/A		
27-Nov-03	Eastport	To support planned upgrade of GLV-02	N/A		
01-Dec-03	Eastport	To support planned upgrade of GLV-02	N/A	12,165	3,790
02-Dec-03	Eastport	To support planned upgrade of GLV-02	N/A		
03-Dec-03	Eastport	To support planned upgrade of GLV-02	N/A		
01-Apr-04	Trepassey	Testing	0.5	1,053	15
02-Apr-04	Trepassey	Testing to troubleshoot generator	1.0		289
12-May-04	Trepassey	Testing	1.5		278
20-May-04	Trepassey	Testing	0.4	1,767	92
23-Jun-04	Trepassey	Testing	0.6	500	1,382
05-Aug-04	Trepassey	Testing	0.2	751	N/A
10-Aug-04	Trepassey	Testing	0.5		N/A
17-Aug-04	Trepassey	Testing	0.1		N/A
19-Aug-04	Trepassey	Testing & Maintenance	1.3		N/A
06-Oct-04	Trepassey	Testing	1.2	1,770	388
19-Oct-04	Trepassey	Testing for Replaced Governor	0.2	N/A	3
16-Nov-04	Trepassey	Testing	0.5	1,283	53

<b>Table 1</b> <b>Usage History of 1.5 MW Portable Generation Unit</b>					
<b>Date</b>	<b>Location</b>	<b>Purpose</b>	<b>Run Time (HRS)</b>	<b>Generation (kWh)</b>	<b>Fuel Used (L)</b>
23-Nov-04	Trepassey	Testing for Nexus Meter	0.5		37
21-Dec-04	Trepassey	Testing & Monthly Inspection	1.0		181
21-Jan-05	Trepassey	Testing	N/A	1,112	N/A
27-Jan-05	Trepassey	Testing	1.7		315
14-Feb-05	Trepassey	Testing to Repair Synchronizing	0.4	2,750	N/A
16-Feb-05	Trepassey	Testing	0.8		91
18-Feb-05	Trepassey	Testing	2.0	958	656
18-Mar-05	Trepassey	Testing	1.3	780	247
28-Apr-05	Trepassey	Testing	1.0		210
04-May-05	Trepassey	Testing for Heater Replacement	N/A	N/A	9
27-May-05	Trepassey	Testing	1.0	628	170
29-Jun-05	Trepassey	Testing & Monthly Inspection	1.5	1,182	320

1