

**Q. Does Newfoundland Power have SAIDI for other Canadian utilities in extreme conditions as outlined in Chart 10? If so, please provide this information.**

**A** Newfoundland Power has aggregate data on SAIDI due to extreme events for other Canadian utilities. The data for the Canadian Electricity Association's Region 2 (utilities with an urban/rural mix) is detailed in Table 1.

**Table 1**  
**SAIDI - CEA Region 2**  
**Extreme Events**

1998	28.79
1999	0.00
2000	0.00
2001	0.00
2002	0.00
2003	4.22
2004	0.00
2005	0.00
2006	5.10
2007	0.64
2008	2.40
2009	0.00
2010	1.20
2011	1.30
2012	0.25
2013	2.36
2014	1.00

The aggregate SAIDI is determined by dividing the total customer minutes due to extreme events by the total number of customers served by all reporting utilities. The impact on the individual utilities affected would be significantly higher.