A. The number of equipment failures by type for the period 2013 - 2015 year to date is detailed in Table 1.<sup>1</sup>

Table 1 Number of Equipment Failures By Type

	2013	2014	2015 YTD
Primary Conductor	198	164	129
Secondary Conductor	51	87	83
U/G Cable	10	9	13
Distribution Transformer	189	192	165
Services/Connections	1,067	1,131	894
Pole	19	13	7
Crossarm	21	9	9
Insulators	114	84	56
Cutout	191	262	200
Lightning Arrestor	27	18	30
Substation Equipment	57	25	23
	1,944	1,994	1,609

<sup>&</sup>lt;sup>1</sup> 2015 data is as of November 30<sup>th</sup>, 2015.