

- 1 **Q. Page 2-12, lines 8-10: Please update the avoided fuel costs for the energy savings of**
2 **50 GWh using Hydro's updated October 2015 forecast fuel cost of \$64.41 per barrel**
3 **(\$Can).**
4
5 A. The updated fuel costs for the energy savings of 50 GWh translates into avoided fuel
6 costs of approximately \$5.1 million.¹

¹ The cost of fuel associated with electricity generated at Holyrood is currently estimated at \$0.102/kWh. This is based upon a 630 kWh/barrel conversion efficiency and oil price forecast of \$64.41/barrel for 2015 as reflected in Hydro's updated October 2015 forecast fuel cost (50,000,000 kWh X \$0.102 = \$5,100,000).