

1 Q. (Reference 2017 GRA Volume I, page 3.12) It is stated (lines 3 to 6) *“in 2016,*
2 *Holyrood Units 1 and 2 were derated due to airflow and reheater tube limitations,*
3 *and Holyrood Unit 3 was derated due to issues with broken generator leads, failed*
4 *west fuel oil pump, air heater fouling, and fouling on the water intake.”* What is the
5 current status of Holyrood TGS? Have these problems been addressed, and does
6 Hydro believe that Holyrood is now capable of operation at full availability?

7
8

9 A. The Holyrood Thermal Generating Station is currently concluding its annual outage
10 maintenance in preparation for the upcoming winter operating season.

11

12 The listed deficiencies have been addressed through corrective maintenance
13 activities during 2016 and 2017.

14

15 With the completion of these corrective actions in 2016 and the execution of its
16 planned outage maintenance in 2017, Holyrood is expected to operate to its
17 planned capacity and availability.