

1 Q. (Reference 2017 GRA Volume I) In the Liberty Report of February 2017 Liberty has  
2 informed the Board that there could be less than 110 MW of recall available given  
3 all of the foregoing. Please advise if the Applicant concurs with Liberty's  
4 conclusion? If only 110 MW are available, how will that affect the Applicant's  
5 calculations on the fund to be created in Nalcor's scheme?  
6  
7

8 A. Hydro's analysis on the amount of thermal generation that can be displaced as a  
9 result of access to recapture energy in excess of Labrador Interconnected System  
10 requirements has assumed the firm availability of 110 MW.  
11

12 Further, as this focuses on the economic dispatch of Hydro's resources with the  
13 addition of energy from recapture to displace thermal generation, the availability of  
14 less or more than 110 MW will not affect how the deferral account balance is  
15 calculated, but will affect the amount of savings realized over the period.