

1 Q. (Reference response to CA-NLH-34) The response indicates that Nalcor is not  
2 required to pay for transport of power and energy on the Maritime Link, but other  
3 entities might be so required. Please identify which of the following facilities will be  
4 included in Hydro's open access transmission tariff: Labrador network transmission,  
5 LTA, LIL, Island network transmission and the ML. For those facilities that are not  
6 included in Hydro's open access transmission tariff, please explain who owns these  
7 facilities, who will be required to pay for them and how.

8  
9

10 A. The facilities listed that will be included in Hydro's open access transmission tariff  
11 are: the Labrador network transmission; the Labrador Transmission Assets (LTA);  
12 the Labrador-Island Link (LIL); the ac portion of the Bottom Brook Terminal Station  
13 #2; TL269; the Granite Canal Tap; and the Island network transmission system.

14

15 The facilities that will not be included in Hydro's open access transmission tariff are:  
16 the HVdc portion of the Bottom Brook Terminal Station #2; the Maritime Link (ML)  
17 (L2001/L2002); and the electrode line. These facilities are owned by Emera. The  
18 questions of who will be required to pay for these facilities, and how, fall within the  
19 purview of the Nova Scotia Utility and Review Board to determine.