

1 Q. **Preamble:** IOC seeks to understand the rates and methodology used to  
2 determine the transmission losses applicable to IOC's rates and  
3 invoices.

4  
5 Also, RFI IOC-NLH-019 was misinterpreted by NLH. In this RFI, "said  
6 transmission loss factor" referred not to the illustration of the Island  
7 loss factor, but to the transmission loss factor of the previous RFI.  
8 IOC therefore restates its RFI.

9

10 **References:** (i) IOC-NLH-009, page 1

11

12 Please define what an "eligible Transmission Customer" is and whether IOC is an  
13 "eligible Transmission Customer"?

14

15

16 A. In accordance with Hydro's approved Schedule of Rates, Rules and Regulations LAB-  
17 IND-1, customers eligible for the Labrador Industrial Transmission rate are defined  
18 as:

19 *Any person purchasing power, other than a retailer, supplied from*  
20 *the Labrador Interconnected bulk transmission grid at voltages of 66*  
21 *kV or greater on the primary side of any transformation equipment*  
22 *directly supplying the person and has entered into a contract with*  
23 *Hydro for the purchase of power and energy (Labrador Industrial*  
24 *Customer).*

25

26 IOC meets the above definition and is therefore subject to the Labrador Industrial  
27 Transmission rate that is approved by the Board. Please refer to Hydro's response

- 1 to IOC-NLH-018 for the transmission losses used in the derivation of the Labrador
- 2 Industrial Transmission demand rate.