

1 Q. **Volume 1 (1st Revision), Chapter 3: Operations**

2 Please provide a table that shows T-SAIFI and T-SAIDI with planned and unplanned
 3 outages shown separately for the years 2007-2016. (Volume I (1st Revision),
 4 Chapter 3: Operations, Page 3.10, Lines 6-7)

5
 6
 7 A. The tables below show the T-SAIFI and T-SAIDI for planned and forced outages for
 8 the years 2007 to 2016. The tables are as follows:

Table 3-3 (i) Transmission Performance (Forced Outages) – All Regions

	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016
T-SAIFI	1.75	0.95	0.38	1.38	3.49	1.32	2.59	2.90	1.53	1.88
T-SAIDI	104.73	63.29	13.53	41.27	220.59	45.54	276.53	214.05	115.65	126.45

Table 3-3 (ii) Transmission Performance (Planned Outages) – All Regions

	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016
T-SAIFI	1.03	0.74	0.52	0.93	0.98	0.55	0.86	0.88	1.57	0.98
T-SAIDI	81.83	214.81	86.76	132.18	195.13	125.25	191.92	243.66	360.98	198.28

Table 3-3 (iii) Transmission Performance (Planned and Forced Outages) - All Regions

	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016
T-SAIFI	2.78	1.69	0.90	2.31	4.47	1.87	3.45	3.78	3.10	2.86
T-SAIDI	186.56	278.10	100.29	173.45	415.72	170.79	468.45 ¹	457.71 ²	476.63	324.73

¹ This change has been addressed in Hydro’s 2017 General Rate Application - Revision 2, filed with the Board on October 16, 2017.

² This change has been addressed in Hydro’s 2017 General Rate Application - Revision 2, filed with the Board on October 16, 2017.