

1 Q. Reference: Supply Cost Deferrals 2015, 2016 and 2017 Application Evidence,  
2 Appendix B, Specific Examples of the Requirement for Standby Generation, page  
3 4, lines 2–3 and Figure 1.

4

5 *“During this week, standby generation was required to support both load and Island*  
6 *spinning reserves from December 28-30, 2015.”*

7

8 Complete the table below providing the maximum load on each unit. In light of the  
9 loads indicated, and the derating of Unit 1 to 155 MW, please explain why the 170  
10 MW spinning reserve target in Figure 1 was appropriate.

Date	Holyrood Unit 1 (MW)	Holyrood Unit 2 (MW)	Holyrood Unit 3 (MW)
28-Dec-2015			
29-Dec-2015			
30-Dec-2015			

11

12

13 A. Table 1 provides the availability of each Holyrood Unit for the dates requested. The  
14 170 MW spinning reserve target in Figure 1 was based on the availability of  
15 Holyrood Unit 2.

**Table 1 - Capability of Holyrood Units (MW)**

Date	Holyrood Unit 1 (MW)	Holyrood Unit 2 (MW)	Holyrood Unit 3 (MW)
28-Dec-2015	155	170	150
29-Dec-2015	155	170	150
30-Dec-2015	155	170	150