

1 Q. **Reference: Supply Cost Deferrals 2015, 2016 and 2017 Application Evidence,**
2 **Pages 22, Table 8: Holyrood Gas Turbine 2016 Operating Data [revised].**

3

4 In Table 8, Hydro indicates that the Holyrood GT was operated for spinning reserve
5 54 times in 2016, for a total of 347.2 actual operating hours. Please provide the
6 total cost of fuel consumed in operating the Holyrood GT in 2016 for spinning
7 reserve.

8

9

10 A. The total cost of fuel consumed in operating the Holyrood GT for spinning reserve in
11 2016 was approximately \$4.2 million.