

1 Q. Further to the response to PUB-NLH-046, please confirm, or correct if necessary,
2 that Hydro maintains the following supply reserves.

3 Spinning Reserve: Capacity of the largest generating unit (170 MW when
4 either Holyrood Unit 1 or Unit 2 is online, otherwise
5 154 MW)

6 Plus

7 Additional Reserve: 70 MW minimum

8 Equals

9 Total Minimum Reserve: 240 MW (with Holyrood Unit 1 or Unit 2), otherwise
10 224 MW

11

12

13 A. It is not confirmed. Hydro's total reserve is 240MW (or 224MW). The 240 MW, with
14 Holyrood Unit or Unit 2, otherwise 224MW, represents Hydro's total reserve, not
15 Hydro's total minimum reserve.