

1 Q. Reference: Hydro’s 2017 General Rate Application Compliance Application, July 11, 2019,  
2 Exhibit 3, Test Year Supply Costs, Page 7, Lines 10-14.

3  
4 “The off-island purchases forecast is materially lower (234 GWh) in the 2019 Test Year as  
5 compared to the October 2018 Filing due to an extended outage of the Labrador-Island Link  
6 forecast to take place during the period of May to October 2019 (inclusive), which results in  
7 lower than anticipated Recapture Energy purchases. The duration of this outage was not known  
8 at the time of preparation of the supply cost forecast included in the October 2018 Filing.”

9  
10 Please provide a table showing the monthly forecast of energy supply (in GWh) over the  
11 Labrador-Island Link for the 2019 Test Year.

12  
13  
14 A. Table 1 shows the monthly forecast of energy supply (in GWh) delivered to Soldiers Pond over  
15 the Labrador-Island Link in the 2019 Test Year.

**Table 1: 2019 Test Year Forecast of Energy Supply Delivered Over the Labrador-Island Link (GWh)**

<b>Month</b>	<b>Forecast of Energy Supply</b>
January	66.95
February	23.60
March	51.40
April	65.35
May	-
June	-
July	-
August	-
September	-
October	7.76
November	78.43
December	47.48
<b>Total</b>	<b>340.97</b>