

- 1 **Q. Further to PUB-NP-001, please provide in Excel file format, a breakdown between**
2 **Newfoundland Power’s sales and Newfoundland Power’s system losses for GWh**
3 **load and MW peak demand by month.**
4
- 5 A. Information relating to energy sales and system losses on a monthly basis for 2008 to
6 2023 is provided in Attachment A to response to Information Request PUB-NP-001.
7
- 8 Newfoundland Power does not record a breakdown of monthly peak demand by sales and
9 system losses.
- 10
- 11 Newfoundland Power does estimate a breakdown of system losses at time of system peak
12 demand for purposes of its Cost of Service Study used to allocate costs to each class of
13 service. At the time of the annual system peak it is estimated that approximately 7.4% of
14 the Company’s Native Load is related to system losses.¹

¹ Newfoundland Power’s Native Load is based on the total of the Company’s power produced and purchased.