

1 Q. Please provide the numbers of Newfoundland Hydro transmission lines, by voltage
2 levels.

3

4

5 A. The number of Hydro owned transmission lines, by voltage levels are as follows:

6 - 69 kV – 14

7 - 138kV – 18

8 - 230kV – 29

9 Note: In addition to the lines owned by Hydro, additional lines are as follows
10 (numbers are not included in totals listed above):

11 - TL264 – 69 kV

12 • Customer owned line from Buchans to Duck Pond, Hydro is responsible
13 for maintenance and asset planning through an agreement;

14 - TL280 - 69 kV

15 • Customer owned line from Star Lake to Buchans, Hydro is responsible for
16 maintenance and asset planning through an agreement;

17 - L150 – 69kV - 18 km

18 • Customer owned line from Bishop’s Falls to Grand Falls, Hydro is
19 responsible for maintenance and asset planning through an agreement;

20 - L2303 (aka. L23) – 230 kV

21 • Churchill Falls to Wabush (line is leased by Hydro from Churchill Falls
22 Corporation (CFLCo)). Maintenance on these lines is performed by
23 Churchill CFLCo through an agreement with Hydro, with Hydro
24 responsible for asset planning); and

25 - L2304 (aka. L24) - 230 kV

- 1 • Churchill Falls to Wabush (line is leased by Hydro from CFLCo).
- 2 Maintenance on these lines is performed by CFLCo through an
- 3 agreement with Hydro, with Hydro responsible for asset planning.