

1 Q. **Holyrood Overview**

2 If the Holyrood plant is expected to continue to take delivery of fuel, for power
3 production purposes (excluding the 100 MW gas turbine deliveries) from 2022
4 onwards, has Hydro, in its Capital Plan, taken fully into account the capital projects
5 necessary or prudent to take, store and handle such deliveries from 2022 onwards?
6 If not, what are the capital projects that can be foreseeably expected to be
7 necessary or prudent to maintain Holyrood's ability to take, store and handle such
8 deliveries from 2022 onwards?

9

10

11 A. The Holyrood plant is not expected to generate power or take bunker fuel deliveries
12 in 2022 and onwards, and therefore no capital projects are in the plan for this
13 system. At this time, Hydro has not performed any investigations into what may be
14 required for storage and handling beyond 2022.