

1 Q. **Reference: Letter from NLH to the Board, dated November 30, 2018**

2 Load

3 Has the demand diminished by 1.5 to 2 MW since the municipality of Happy-Valley
4 – Goose Bay issued a stop work order to Crypto Boreas?

5

6

7 A. The Base Coincident Peak forecast for Labrador East reflects a 1.2 MW load
8 requirement from this customer. As Newfoundland and Labrador Hydro has already
9 agreed to provide service to this customer, it does not consider it reasonable to
10 refuse service should the customer become established, subject to Board Order No.
11 P.U. 36(2018).