

**2018 Capital Budget Application – Revised Information pursuant to Order P.U. 43(2017) –
Muskrat Falls to Happy Valley Interconnection Project**

- 1 Q. Please confirm that:
- 2 a. the service requests that Hydro currently has for Labrador East exceed 32 MW
- 3 including the 8.6 MW for which service contracts are in place.
- 4 b. the service requests that Hydro currently has for Labrador East exceed the
- 5 design capacity of the Muskrat Falls to Happy Valley Interconnection as applied
- 6 for in the present proceeding.
- 7 c. Hydro has received inquiries for 200 MW in Labrador East.
- 8 d. If Hydro cannot confirm any of (a), (b) or (c), please explain why.
- 9
- 10
- 11 A. For item a, the 32 MW of service requests are in addition to the 8.6 MW already
- 12 committed. Items b and c are confirmed.