

1 Q. **Re: NLH, Attachment 1, Responses to PUB Questions, page 2**

2 Citation:

3 Table 1 provides actual peak demands for the Happy Valley-Goose Bay system since  
4 the winter of 2000/2001.

5

6 The 2017/2018 peak of 66.9 MW (to February 28, 2018) is less than the forecast  
7 requirement of 79.9 MW primarily because the connected data centre customer  
8 loads have not ramped up to operational load requirements. In addition, the  
9 temperatures during system peak periods for the current winter to date have been  
10 milder than normal peak period weather conditions for this region.

11

12 Preamble:

13 Table 1 shows peak loads of 71.1 MW in 2016/17 (the historic high), and of 66.9  
14 MW in 2017-18p.

15

16 a) Please provide the actual peak load in the winter of 2017/18.

17 b) Please provide:

18 i) the forecast peak load in the winter of 2018/19,

19 ii) the forecast peak load in the winter of 2018/19 without the 5.5 MW  
20 interruptible contract with Labrador Lynx Ltd.,

21 iii) the forecast peak load in the winter of 2018/19 without any data centre  
22 loads, and

23 iv) the forecast peak load in the winter of 2018/19 under the hypothesis that all  
24 data centre loads are curtailed for the peak 300 hours of the year.

1 A.

2 a) The actual peak load for the Labrador East system in the winter of 2017-2018  
3 was 66.9 MW and occurred on January 15, 2018 at 0900 hours.

4

5 b)

6 i) Please refer to the Labrador East Base Coincident Peak Forecast on page 11  
7 of the “Labrador Interconnected System Transmission Expansion Study” for  
8 the most recent peak load forecast. The forecast P90 peak demand for the  
9 Labrador East system for the winter of 2018-2019 is 81.7 MW. The  
10 corresponding forecast P50 peak demand for the Labrador East system for  
11 the winter of 2018-2019 is 78.7 MW. Neither the P90 nor the P50 peak  
12 demand forecasts consider the impact of the temporary interruptible  
13 contract with Labrador Lynx Ltd.

14

15 ii) As indicated in i), the forecast peak load for the winter of 2018-2019 does  
16 not consider the impact of the temporary interruptible contract with  
17 Labrador Lynx Ltd. However, to assist in understanding the potential of the  
18 interruptible contract in reducing actual demand, the forecast system  
19 coincident peak demand for Labrador Lynx Ltd. for the winter of 2018-2019  
20 is 4.4 MW including distribution losses. The impact of the interruptible  
21 contract on reducing actual demand will depend on the actual load  
22 requirements of Labrador Lynx Ltd. when required to reduce load.

23

24 iii) Newfoundland and Labrador Hydro’s (“Hydro”) Labrador East Base  
25 Coincident Peak Forecast presented on page 11 of the “Labrador  
26 Interconnected System Transmission Expansion Study” specifically  
27 accounted for three new service requests identified as data centres. The  
28 forecast system coincident peak demand for the three new service requests

**2018 Capital Budget Application – Muskrat Falls to Happy Valley Interconnection Project**

1 identified as data centres for the winter of 2018-2019 is 6.3 MW including  
2 distribution losses. Additionally, please refer to Hydro’s response to LAB-  
3 NLH-035(d).

4

5 iv) Hydro does not have the authority to curtail customers in this fashion.  
6 Therefore, the calculations necessary to provide this information have not  
7 been made as such an exercise will not contribute to the value of the  
8 current proceeding.