

- 1 Q. **Tab 2; Volume II: Increase Fuel & Water Treatment System Capacity**
2 How did Hydro determine that the proper fuel storage capacity needs to increase to
3 5 million litres?
4
5
- 6 A. Please refer to Hydro's response to NP-NLH-014. The level of storage being
7 proposed for the Holyrood gas turbine is consistent with the amount of fuel storage
8 currently in place at Hardwoods gas turbine, which allows for five days operation at
9 full load without fuel deliveries.