

1 Q. **Tab 6; Volume II: Install Remote Operation of Salmon River Spillway**
 2 Please provide a listing of spillways in Hydro’s hydraulic system and indicate
 3 whether or not each site has remote control capabilities.

4
 5

6 A. The following table identifies each of the spillways in Hydro’s hydraulic system and
 7 their method of control:

Spillway	Design	Remote Capability
Salmon River Spillway	Gated	No
West Salmon Spillway	Gated	Yes
North Salmon Spillway	Gated	Yes
Granite By-Pass	Gated	Yes
Burnt Dam Spillway	Gated	No – Staffed site, 24hours a day, 365 days a year.
Victoria Spillway	Overflow	N/A
Paradise River Spillway	Overflow	N/A
Cat Arm Spillway	Overflow	N/A
Hinds Lake Spillway	Gated	Yes
Star Lake Spillway	Overflow	N/A
Snook’s Arm Spillway	Overflow	N/A
Venam’s Bight	Overflow	N/A