

1 Q. **Tab 19; Volume II: Replace Transformer T1 - Buchans**

2 Hydro indicates the least cost alternative for this project is to replace the existing  
3 Buchans' T1 transformer with a spare 230:66 kV, 40/53.3/66.6 MVA transformer  
4 currently located at the Hardwoods Terminal Station. In keeping with Hydro's Asset  
5 Management Program will the spare transformer removed from the Hardwoods  
6 Terminal Station have to be replaced? If yes, was this considered in the cumulative  
7 net present worth analysis?

8

9

10 A. No. The spare transformer that is to replace Buchans T1 is a redundant spare and  
11 therefore will not be replaced.