

1 Q. Reference page 6, lines 8-9, Labrador Interconnected System Network Additions Policy –
2 Summary Report.

3

4 How was the 1500 kW threshold for more detailed system impact reviews determined?

5

6

7 A. The 1500 kW threshold was selected on the basis that an interconnection request of this
8 magnitude would have the potential to accelerate the Transmission Expansion Plan and
9 necessitate for further analysis to assess the cost of interconnection requirements and
10 reliability impacts. This value was selected in the context of forecasted baseline load
11 growth in the Labrador Interconnected Transmission System and was deemed to be
12 sufficiently larger than the 300 kW of growth per year in western Labrador and 500 kW of
13 growth per year in eastern Labrador. A load increase of this magnitude would therefore
14 have an appreciable impact of the load forecast and system expansion requirements.