
1 Q. **Reference: 2018 Cost of Service Methodology Review Report dated November 15, 2018**


2

3 On page 12 (lines 10 to 12) it is stated *“Hydro recommends that the cost of wind purchases*
4 *be classified as 22% demand and 78% energy reflecting the “Effective Load Carrying*
5 *Capability Study” conducted by Hydro’s resource planning group regarding wind availability*
6 *during peak periods”*. Please file a copy of this report for the record.

7

8

9 A. Please see CA-NLH-011, Attachment 1 for a copy of the “Effective Load Carrying Capability
10 Study Newfoundland and Labrador Hydro Wind Turbines”, filed on November 16, 2018,
11 with the Board of Commissioners of Public Utilities as Volume 1, Attachment 6 of the
12 “Reliability and Resource Adequacy Study”.



Effective Load Carrying Capability Study
Newfoundland and Labrador Hydro Wind Turbines

November 2018

A Report to the Board of Commissioners of Public Utilities

Effective Load Carrying Capability Study Newfoundland and Labrador Hydro Wind Turbines

Table of Contents

1 Summary 2

Effective Load Carrying Capability Study Newfoundland and Labrador Hydro Wind Turbines

1 **1 Summary**

2 In 2007, Newfoundland and Labrador Hydro (“Hydro”) secured two, 20-year Power Purchase
3 Agreements for a total of 54 MW of wind generation on the island of Newfoundland; a 27 MW
4 wind project located in St. Lawrence and a 27 MW project located in Fermeuse. The St.
5 Lawrence Wind Farm is located approximately 5 km outside of the community of St. Lawrence
6 on the Burin Peninsula. The farm is comprised of nine, 3.0 MW, Vesta V90 turbines, which have
7 been in operation for nearly ten years. The project is owned and operated by Enel GP
8 Newfoundland and Labrador Inc. and began producing wind power to the electricity grid in
9 October 2008. The Fermeuse Wind Farm is located on the Southern Shore of the Avalon
10 Peninsula. Similarly, the project consists of nine, 3 MW, Vestas V90 turbines which also have
11 been in operation for almost ten years. The farm is owned by SkyPower and operated by EDF
12 Énergies Nouvelles and began supplying wind energy in April 2009.

13
14 Wind generation is an intermittent, non-dispatchable resource, meaning its output cannot be
15 controlled like a conventional resource as the output is dependent on the available wind speed.
16 Production can also be challenging in times of very low or very high wind speeds. Low wind
17 speeds may not reach the minimum wind speed required for the turbines to produce energy.
18 Conversely, if wind speeds are too high, turbines may reach cut out speed, at which the
19 turbines will shut down to prevent damage. Previously, under the Isolated Island System, Hydro
20 has not relied upon wind farms as a reliable contribution to the islands firm capacity, meaning
21 that wind generation was considered as purely energy on a planning basis.

22
23 Given the interconnection to the North American grid, as part of its Reliability Model, Hydro re-
24 evaluated the contribution of wind generation to system capacity. Utilities across North
25 America use a variety of methods to determine the capacity contribution of intermittent
26 sources. A common approach is to use the concept of effective load carrying capability
27 (“ELCC”). The ELCC of a unit is a measure of the additional load that the system can supply with
28 the particular generator of interest, with no net change in reliability.

Effective Load Carrying Capability Study Newfoundland and Labrador Hydro Wind Turbines

1 In order to determine the ELCC of the existing wind generation an ELCC study was performed.
2 The ELCC study looked at the two existing wind farms on the island. It is assumed that new wind
3 generation would have a similar generation profile to the existing wind farms. Therefore the
4 ELCC determined in the study can be assumed to be applicable to all existing and new wind
5 farms.
6
7 The ELCC study was completed using the PLEXOS model. The historical hourly wind generation
8 data from January 2010 to June 2018 for both the Fermeuse and St. Lawrence wind farms was
9 analyzed, resulting in a probability distribution for the wind generation in percentage by MW.
10 The distribution was separated into winter (December to March) and non-winter (April to
11 November) to more accurately determine the effect of the wind generation in the winter
12 months where loss of load is more likely to occur. The distribution was then input into the
13 PLEXOS model as a probability distribution representing each respective wind farm during the
14 summer and winter periods. See Figure 1 to Figure 4 for the winter and non-winter generation
15 profiles of each wind farm.




Figure 1: Fermuse Wind Farm Winter Generation Profile

Effective Load Carrying Capability Study Newfoundland and Labrador Hydro Wind Turbines




Figure 2: Fermuse Wind Farm Non-Winter Generation Profile




Figure 3: St. Lawrence Wind Farm Winter Generation Profile

Effective Load Carrying Capability Study Newfoundland and Labrador Hydro Wind Turbines




Figure 4: St. Lawrence Wind Farm Non-Winter Generation Profile

- 1 The steps taken to complete the ELCC study in PLEXOS® are as follows:
- 2 1) Run the model with both wind farms included in the system model. For this model, the
- 3 wind farms were modeled using the probability curves described above.
- 4 2) Adjust loads using an escalator value in PLEXOS®, which linearly scales the system load,
- 5 until the system loss of load hours (“LOLH”) reaches 2.8 hours per year. Starting with a
- 6 baseline LOLH of 2.8 allows the effect of changing generation resources to be clearly
- 7 seen.
- 8 3) Remove both wind farms from the system and run the model again to determine the
- 9 effect on system LOLH.
- 10 4) Add an “ideal” generator to the system with a capacity close to the expected ELCC value
- 11 and rerun the model
- 12 5) Adjust the capacity of the ideal unit up or down and rerun the model until the system
- 13 LOLH returns to 2.8.
- 14 6) The capacity of the ideal generator which produces a system LOLH of 2.8 determines the
- 15 ELCC of the wind units.

Effective Load Carrying Capability Study Newfoundland and Labrador Hydro Wind Turbines

- 1 The study found that the ELCC of the existing wind generators was approximately 12 MW, or
- 2 22%, based on an installed capacity of 54 MW.