
1 Q. At page 1 of Schedule 1 of the 2018 COS Methodology Review Report, lines 14-16, it is
2 noted that *“prior to the accessibility of off island purchases, approximately 85% of the test
3 year revenue requirement related to Holyrood was classified as energy-related costs.”*

4
5 Please indicate how much of the Holyrood generation is expected to be replaced by
6 Maritime Link purchases.

7
8
9 A. Upon the full commissioning of the Muskrat Falls Project, Newfoundland and Labrador
10 Hydro would not be forecasting energy purchases over the Maritime Link.