

1 Q. **Reference: Study, section 3, page 13, lines 1-5**

2 Preamble:

3
4
5
6
7
8
9

“For the purposes of this investigation, the baseline load forecast includes load increases associated with Tacora operations at the Wabush Mines site. Hydro currently receives monthly power on order requests to accommodate the ramp up of this operation. The transmission system expansion plans developed in this report are designed to accommodate the full operation of this facility.”

10 Provide the monthly power on order requests received from Tacora.

11
12

13 A. Please refer to Table 1 for the monthly Power on Order requests received from Tacora

14 Resources.

Table 1: Requests from Tacora Resources

Date	Power on Order (kW)	Actual Maximum Demand (kW)
July 2018	3,000	2,209
August 2018	3,000	2,217
September 2018	3,000	2,378
October 2018	13,000	7,572
November 2018	13,000	9,475
December 2018	13,000	11,666
January 2019	13,000	12,997
February 2019	13,000	14,495