

1 Q. Reference page 5, lines 10-14, *Labrador Interconnected System Network Additions Policy*  
2 *Summary Report*

3 a. Clarify if the capacity in Table 1 is the total capacity of the upgrade or the incremental  
4 capacity of the upgrade.

5 b. Explain how the incremental capacity was calculated.  
6  
7

8 A. a. The values listed in Table 1 of the “Labrador Interconnected System Transmission Expansion  
9 Study”<sup>1</sup> (“Study”) refer to incremental capacities that are afforded by each transmission system  
10 upgrade.  
11

12 b. Incremental capacity values were determined using load flow analysis as presented in the  
13 Study. Labrador East solutions are presented in Appendix A of the Study and Labrador West  
14 solutions are presented in Appendix D.

---

<sup>1</sup> Filed with the Board of Commissioners of Public Utilities on December 14, 2018.