

1 Q. **References: Tab 9; Volume II: Overhaul Diesel Units – Various**

2 Hydro states on page 12, lines 16-18, *“The recommendation on diesel engine*  
3 *overhauls made as part of this review states that ‘parts being removed from the*  
4 *units have sustained very little wear and the overhaul can very easily be extended to*  
5 *20,000 hours.’”*

6  
7 Has Hydro considered further extending the period between diesel engine  
8 overhauls (e.g., 25,000 hours) given the very easy nature of the previous extension  
9 recommended in the 2003 review undertaken by Hydro?

10  
11

12 A. Hydro is currently reviewing the maintenance strategy for its diesel engines,  
13 including overhaul timing. The focus of the review is to ensure that the  
14 maintenance regimes accurately fit the two types of units currently in operation,  
15 1200 rpm and 1800 rpm units. The review will be completed by the end of 2018 and  
16 changes to overhaul timing will be reflected in the 2020 Capital Budget Application.