

1 Q. **Reference: Tab 12; Volume II: Diesel Genset Replacements (2021-2022)**

2 What impact, if any, does the 1.8 MW Nain Wind Micro Grid Project have on the decision to
3 replace this genset in 2021?

4

5

6 A. The Nain Wind Micro Grid Project will not impact on the decision to replace Nain Unit 594 in
7 2021. The replacement of Unit 594 is required in order for Newfoundland and Labrador Hydro
8 (“Hydro”) to meet its firm capacity criteria and the Nain Wind Micro Grid Project would only
9 provide non-firm generation for fuel displacement. Additional information on why Hydro does
10 not considered wind generation a firm source of electricity is provided in Hydro’s response to
11 CA-NLH-069 of this proceeding.