

1 Q. Further to Hydro's response to NP-NLH-008, what mode of operation (# of units, minimal  
2 loadings, etc.) of the Holyrood TGS is reflected in the consumption provided in this response?

3

4

5 A. The forecast fuel consumption for the Holyrood Thermal Generating Station reflects operation  
6 of one unit from September 9, 2021 to March 31, 2022 and operation of a second unit from  
7 October 17, 2021 to November 15, 2021. All operation is forecast using a minimum unit loading  
8 of 50 MW.