

- 1 **Q. (Reference Application Volume 2, 2021 Additions Due to Load Growth, Attachment**
2 **A, page 5) If the low load growth forecast materializes, do you need to make any**
3 **changes to the substation? Please explain.**
4
- 5 A. Yes. If the low load growth forecast materializes, DUN-T1 would still overload and
6 substation upgrades would be required. The peak load forecasts for the sensitivity
7 analysis are shown in appendices C, D and E of Attachment A to report 2.2 *2021*
8 *Additions Due to Load Growth.*