

- 1 **Q. (a) What is the overall improvement in SAIDI and SAIFI proposed from the**  
2 **projects included in the 2021 Capital Budget?**  
3  
4 **(b) What is NP's current policy objectives and targets with respect to reliability,**  
5 **more particularly SAIDI and SAIFI?**  
6  
7 **(c) Please provide on a list the last ten years of actual Capital Budget expenditures**  
8 **for each year and the SAIDI and SAIFI for that year.**  
9  
10 **(d) Please provide evidence as to what utility Boards across the country determine**  
11 **should be the evidentiary weight for SAIDI and SAIFI in determining whether a**  
12 **project should be approved for expenditure.**  
13  
14 **A. (a) Newfoundland Power is not proposing an *overall* improvement in SAIDI and SAIFI**  
15 **from projects included in the *2021 Capital Budget Application*.**  
16  
17 **(b) The current policy objective and targets with respect to SAIDI is to maintain a SAIDI**  
18 **level based on the most recent 5-year average. Newfoundland Power does not target**  
19 **SAIFI.**  
20  
21 **(c) See response to Request for Information CA-NP-004.**  
22  
23 **(d) Newfoundland Power is not aware of any evidence as to what utility boards across the**  
24 **country determine should be the evidentiary weight for SAIDI and SAIFI in**  
25 **determining whether a project should be approved for expenditure.**