

1 **Q. Reference: “2021 Capital Budget Application,” Newfoundland Power, July 9, 2020,**
2 **Volume 2, Feeder Additions for Load Growth at p.2.**

3
4 **Citation:**

5
6 **There are several alternatives for addressing conductor overload conditions.**

7
8 **Does Newfoundland Power consider voltage conversions without load transfers as a**
9 **means to address conductor overload? If not, why not?**

10
11 A. Yes. Where it is technically and economically viable Newfoundland Power will, as part
12 of its distribution planning analysis of alternatives, consider voltage conversion as a
13 means to address conductor overload. For all conductor overload conditions addressed as
14 part of the *2021 Feeder Additions for Load Growth* project voltage conversion was
15 determined not to be a viable alternative.