

1 Q. **Reference: Application, paragraph 14.**

2 Please describe the scope of work associated with the winterization of Unit 2102 at  
3 Charlottetown.

4

5

6 A. The onboard radiator, fan, and aftercooler will be removed from Unit 2102 and will be replaced  
7 with a remote skid-mounted radiator and aftercooler. This greatly reduces the amount of air  
8 being sucked into the mobile unit, which lowers the risk of sucking in snow and rain that would  
9 damage the engine or generator. Additionally, some minor ventilation modifications will be  
10 performed, including the addition of an appropriately-sized combustion air fan to ensure  
11 enough airflow for the warmer summer months.