

1 Q. **Reference: Application Volume 2, Install Recloser Remote Control (2022) – Various**

2 What are the units for “Definition” used in Table A-1 for Factor 6?

3

4

5 A. The definition column of Table A-1¹ for Factor 6 uses the System Average Interruption Duration
6 Index (“SAIDI”), which is a measure of average outage duration (in hours) per customer served.
7 For example, in Table A-1 for Factor 6, a SAIDI of fewer than 5 outage hours per customer per
8 year would produce a score of 1 for this particular factor.

¹ “2022 Capital Budget Application,” Newfoundland and Labrador Hydro, rev. September 17, 2021 (originally filed August 2, 2021), vol. II, sch. 7, app. A, at pp. 57–58.