

1 Q. With reference to Section 4.4 – Specifically Assigned Assets for Industrial Customers, please  
2 confirm that no proposed or projected capital expenditures contemplated by the 2022 Capital  
3 Budget Application (or Hydro’s 5-year Capital Plan) will be specifically assigned to NARL Refining  
4 Limited Partnership, Corner Brook Pulp & Paper Limited or Vale Canada Limited.

5

6

7 A. In Newfoundland and Labrador Hydro’s (“Hydro”) original filing of its 2022 Capital Budget  
8 Overview, planned expenditures to be specifically assigned to NARL Refining Limited Partnership  
9 (“NARL”), Tacora Resources (“Tacora”), and Marathon Gold Corporation (“Marathon Gold”) were  
10 inadvertently excluded.<sup>1</sup> This section was subsequently corrected in Revision 1 of Hydro’s  
11 2022 Capital Budget Application, filed on September 17, 2021. For ease of reference, the  
12 corrected Table 1 is included below:

**Table 1: Specifically Assigned Capital Work (2022–2026)**

<b>Customer</b>	<b>Specifically Assigned Work</b>	<b>Project</b>
IOC <sup>2</sup>	Breaker, B3L3, WABTS <sup>3</sup>	Terminal Station Refurbishment and Modernization (2021–2022)
IOC	L3 Protection, IOC 3	Terminal Station Refurbishment and Modernization (2021–2022)
IOC	Breaker, B4L5B, WABTS	Terminal Station Refurbishment and Modernization (2021–2022)
IOC	L5 Primary Protection, IOC 5 a/b	Terminal Station Refurbishment and Modernization (2021–2022)
IOC	Disconnect, B4L6-1	Terminal Station Refurbishment and Modernization (2021–2022)
IOC	WABTS B3L4 Replacement	Upgrade Circuit Breakers (2022–2023)
IOC	WABTS L4 Protection Relay Replacement	Replace Protective Relays – Various (2022–2023)
IOC	WABTS B3L5A Replacement	Upgrade Circuit Breakers (2023–2024)
IOC	WABTS B3L1 Replacement	Upgrade Circuit Breakers (2023–2024)
IOC	WABTS L1 Protection Relay Replacement	Replace Protective Relays – Various (2023–2024)

<sup>1</sup> “2022 Capital Budget Application,” Newfoundland and Labrador Hydro, rev. September 17, 2021 (originally filed August 2, 2021), vol. I, sch. 1, sec. 4.4.

<sup>2</sup> Iron Ore Company of Canada (“IOC”).

<sup>3</sup> Wabush Terminal Station (“WABTS”).

<b>Customer</b>	<b>Specifically Assigned Work</b>	<b>Project</b>
IOC	WABTS B3L5a Breaker Fail Protection Upgrade	Upgrade Circuit Breakers (2023–2024)
IOC	WABTS B4L6 Replacement	Upgrade Circuit Breakers (2026–2027)
NARL	CBC T1 X0 bushing replacement	Upgrade Power Transformers (2023–2024)
NARL	CBC T2 X0 bushing replacement	Upgrade Power Transformers (2023–2024)
NARL	CBC T1 protection replay replacement	Replace Protective Relays – Various (2026–2027)
NARL	CBC T2 protection replay replacement	Replace Protective Relays – Various (2026–2027)
Tacora	WABTS B4L34-1 (formerly 34B15) replacement	Replace Disconnects (2025–2026)
Tacora	WABTS B4L34 replacement	Upgrade Circuit Breakers (2025–2026)
Tacora	WABTS B4L35 replacement	Upgrade Circuit Breakers (2026–2027)
Marathon Gold	Valentine Gold Interconnection	Valentine Gold Interconnection (2021–2023)