

1 Q. What are NL Hydro's sources of Controllable Load Resource and Non-Load Controllable  
2 Resources?

3

4

5 A. Newfoundland and Labrador Hydro ("Hydro") does not use the terms controllable load Resource  
6 and non-controllable load resources.<sup>1</sup> Hydro's review indicates that they are similar to  
7 contracted curtailable loads/capacity assistance agreements and loads that can be interrupted  
8 in emergency cases using Under Frequency Load Shedding ("UFLS") schemes, respectively.

9 For curtailable load/capacity assistance, please refer to Hydro's response to BKL-NLH-092 of this  
10 proceeding.

11 For UFLS, this load reduction approach rests primarily with Newfoundland Power Inc.  
12 customers. Hydro has one UFLS scheme with an Island Industrial customer.

---

<sup>1</sup> Hydro's review of these terms indicated their use in Texas, but Hydro could not find instances of their use in Canadian jurisdictions. Hydro's review also indicated that the second term is "non-controllable load resource," instead of non-load controllable resource.