

1 **Q. Reference: “2022/2023 General Rate Application,” Newfoundland Power, May 27,**
2 **2021, Volume 2, Section 3**

3 **Please provide a table of the last five years of energy and demand actuals.**

4 **A.** Table 1 provides Newfoundland Power’s annual normalized energy sales and weather
5 adjusted peak demand for 2016 to 2020.

**Table 1:
Normalized Energy Sales and Peak Demand
2016 to 2020**

| Year | Energy Sales (GWh)¹ | Weather Adjusted Peak Demand (MW)² |
|-------------|---|--|
| 2016 | 5,950.1 | 1,381.2 |
| 2017 | 5,922.2 | 1,445.9 |
| 2018 | 5,876.1 | 1,384.9 |
| 2019 | 5,846.6 | 1,439.8 |
| 2020 | 5,729.0 | 1,367.3 |

¹ Normalized energy sales as reported on Return 14 in the *Annual Return to the Board* for the years 2016 to 2020.

² The calculation of the native peak is confirmed by Newfoundland and Labrador Hydro by April 5th of each year.