

- 1 **Q. (Reference Application, 1.1 Distribution Reliability Initiative, page 4, Table 1)**  
 2 **Please show the rolling 5-year average for each of the past 5 years.**  
 3  
 4 A. Tables 1 and 2 provide the rolling five-year average distribution interruption statistics for  
 5 each of the past five years for distribution feeder SUM-01 and Newfoundland Power's  
 6 corporate averages.

Table 1 Distribution Interruption Statistics SUM-01 Five-Year Rolling Average				
Year	SAIFI	SAIDI	CHIKM	CIKM
2017	3.43	4.73	75	16
2018	4.02	5.76	92	64
2019	4.68	7.96	125	76
2020	3.80	7.80	124	62
2021	2.89	7.98	125	46

Table 2 Distribution Interruption Statistics Corporate Five-Year Rolling Average				
Year	SAIFI	SAIDI	CHIKM	CIKM
2017	1.35	1.71	44	34
2018	1.37	1.82	55	45
2019	1.39	1.80	52	45
2020	1.33	1.82	50	39
2021	1.37	1.82	49	40