

1 **Re: 2009 Capital Projects: \$500,000 and Over p. B-22 - L'Anse au Loup**

2 **Generation**

3 Q. a) Has the possibility of an eventual connection of the L'Anse Au Loup
4 distribution system to the Lower Churchill HVDC line been considered in
5 formulating the parameters of this project, and if so, how?
6

7

8 A. The connection of the L'Anse au Loup distribution system to the Lower
9 Churchill HVDC line is not economically feasible utilizing current HVDC
10 technology.