

1 **Re: 2009 Capital Projects \$200,000 - \$500,000 p. D-59 - Drainage System -**
2 **Western Avalon**

3 Q. a) Please clarify:

4

5 i) the age of the existing drainage system at the Hydro Western
6 Avalon Terminal Station;

7

8 ii) the anticipated service life of such systems;

9

10 iii) whether the existing system has attained the end of its anticipated
11 service life.

12

13

14 A. i) The age of the existing drainage system at the Hydro Western
15 Avalon Terminal Station is 15 years.

16

17 ii) The anticipated service life of the new system is 20 years.

18

19 iii) The existing system is full of silt and has attained its service life.

20 The new system will use filter fabric which is anticipated to extend its

21 service life by a minimum of five years.