

1 **Re: 2009 Capital Projects: \$500,000 and Over p. B-2 - Holyrood Fuel Storage**
2 **Facility**

3 Q. At page B-3, NLH submits that the proposed upgrades will refurbish the “life
4 of the facility for a further twenty years”.

5

6 a) In the event Holyrood operates as a synchronous condenser following a
7 HVDC infeed from the Lower Churchill Project, will the facility still consume
8 any fuel and if so, approximately how much?

9

10 b) Why is this project classified as ‘normal’ rather than ‘mandatory’?

11

12 c) Other than the Gasoline and Associated Products Regulations referenced
13 at Volume II, Tab 1, Page 12, what other federal or provincial regulations
14 have potential bearing on the issue of fuel storage at Holyrood, and is NLH
15 currently in compliance with them?

16

17 d) Has NLH experienced oil leaks or spills from the Holyrood Tank Farm, and
18 if so, when?

19

20

21 A. a) When Holyrood operates as a synchronous condenser, no fuel will be
22 consumed by the plant for the generation of electrical energy.

23

24 b) The project has been classified as ‘normal’ because Hydro is following
25 guidelines specified by the American Petroleum Institute (API) and the
26 Gasoline and Associated Products Regulations (GAP). The work has not
27 been described as ‘mandatory’ because there is no federal or provincial
28 government legislation directly requiring this work to be done.

1

2

c) The National Fire Code of Canada is referenced in the GAP Regulations,

3

Section 27, as applying to fuel storage tank systems. Part 4 of this code

4

requires that the vegetation be removed from dykes containing fuel tanks.

5

Upon completion of this project, Hydro will be in compliance with this

6

requirement.

7

8

d) There have been no oil leaks or spills from the Holyrood Tank Farm.