

1 **Re: Replace Automatic Voltage Regulator on Gas Turbine**

2 Q. Please indicate the current anticipated useful life of the Stephenville Gas  
3 Turbine.

4

5

6 A. A gas turbine plant has a normal anticipated service life of 25 years. The  
7 Stephenville plant is now 33 years old and has exceeded its anticipated  
8 useful life.