

1 **Re: TL-212 Upgrade**

2 Q. Does Hydro plan to replace the aluminum towers on this line with wooden  
3 structures and, if so, when?

4

5

6 A. There are no plans for a large scale replacement of the aluminum towers  
7 with wooden structures on TL-212. If an aluminum tower fails, it will be  
8 replaced with a wooden structure as was the case for a failure in March.

9

10 To date, the only major problem identified on the towers is the corrosion of  
11 guy wires on the southern section of the line towards the Linton Lake  
12 terminal station. These guy wires will be replaced as part of this project.