

1 **Re: Upgrade Power Transformers**

2 Q. Confirm that Table 7 at p. 16 of Tab 13 shows significantly fewer failures on  
3 Hydro's system than the CEA average and a much lower percentage  
4 unavailability on Hydro's system than the CEA average.

5

6

7 A. Table 7 on p. 16 of Tab 13 shows the frequencies of failures for power  
8 transformers for Hydro compared to the CEA averages. The frequencies for  
9 Hydro for the period 2003 to 2007 are lower than the CEA averages for the  
10 period 2001 to 2005.