

1 **Re: Hardwoods Gas Turbine Plant Life Extension Upgrade**

2 Q. To what use would the Hardwoods and Stephenville turbines be put in the
3 event of a Labrador interconnection?

4

5

6 A. In the event of a Labrador interconnection the Hardwoods and Stephenville
7 gas turbines will be required to provide synchronous condenser support and
8 will also provide emergency backup generation in the event of problems with
9 the HVDC link.