

1 **Re: Hardwoods Gas Turbine Plant Life Extension Upgrade**

2 Q. Would Hardwoods be required either for synchronous condensing or power
3 generation, in addition to the Holyrood Thermal Generating Station, in the
4 event of a Labrador interconnection.

5

6

7 A. In the event of a Labrador interconnection the Hardwoods gas turbine will be
8 required for synchronous condensing and as an emergency backup
9 generation source.