

1 **Upgrade Transmission Line TL-212, \$967,900, Page B-15**

2 Q. The report *TL-212 Upgrade*, Tab 5 Volume 2, page 4, stated that 144 of the  
3 514 towers on TL-212 were inspected in March 2008, with 47 aluminum  
4 towers requiring guy wire replacement. Has the condition of the guy wires on  
5 the remaining 370 structures been assessed?

6

7

8 A. Of the remaining 370 structures, 147 are constructed with wood poles and  
9 have been inspected under the Wood Pole Line Management (WPLM)  
10 Program in 2006 and 2007. The guy wires on the remaining 223 aluminum  
11 towers are scheduled to be inspected during ground patrols in the fall of  
12 2008.