

1 **Re: B-66, Replace Line L36, Wabush, \$498,000**

2 Q. Is it the intention of Hydro to remove the original line L36 from service once
3 the new line has been commissioned and put in service?

4

5

6 A. Yes, once L36 has been commissioned and put in service, it is intended that
7 the original line be decommissioned and removed from service.