

1 **Re: D-100, Replace Fire Protection Panels, Hydro Place, \$89,000**

2 Q. What is the age of the fire protection panels currently in place?

3

4

5 A. The fire protection panels currently in place are the original panels installed  
6 in 1989 when Hydro Place was constructed.